




ELECTRICITY
SWITCHED FUSED SPUR
INSTALLATION MANUAL



BUSTERANDPUNCH.COM
L0084

EN

TECHNICAL SPECIFICATION

13A DP SWITCHED FCU WITH NEON STYLE:
1 GANG
RATED AT 13A 250V~ AC ONLY (FUSE INCLUDED)

IMPORTANT NOTES

PLEASE READ BEFORE INSTALLING

These products must be installed in accordance with the latest Building and IEE wiring regulations. If in any doubt, please contact a qualified electrician.

BACK BOXES

We recommend you to use a UK back box to install your product. Please note that the minimum recommended depth for the mounting box is 37mm. Back boxes are available to purchase from us, please see recommended sizes below:

PLATE	RECOMMENDED BACK BOX
1G	1G UK Back box – SKU# ELB921

WARRANTY INFORMATION

The Warranty Period of Two (2) years from the date of the original purchase.

RECYCLING ELECTRICAL PRODUCTS

Buster and Punch encourages all its customers to make note of this symbol and avoid putting any waste electrical goods in your domestic waste bin or container. Please ensure you take your waste electrical goods to a suitable facility for disposal.



1



BEFORE COMMENCING WORK, ISOLATE THE MAINS POWER SUPPLY AND REMOVE THE FUSE IN THE FUSE BOX OR SWITCH OFF THE CIRCUIT BREAKER IN THE CONSUMER UNIT.



2

IF UNIT IS TO BE USED AS A REPLACEMENT FOR AN EXISTING PRODUCT, REMOVE EXISTING UNIT FROM ITS LOCATION AND DISCONNECT THE WIRING.






CAUTION:
Verify power is OFF to switch before proceeding.

3


CERTAIN ITEMS IN THE RANGE WILL NOT FIT INTO A 4 LUG BOX. IF SUCH A BOX HAS BEEN PREVIOUSLY INSTALLED THE TOP AND BOTTOM LUGS SHOULD BE REMOVED OR BENT BACK TO AVOID CONTACT WITH THE INTERIOR.

4

CONNECT THE WIRES AS SHOWN IN APPROPRIATE WIRING DIAGRAMS. USE GREEN/YELLOW SLEEVING ON EARTH CONDUCTORS. ENSURE TERMINALS ARE PROPERLY TIGHTENED AND NO BARE WIRE IS VISIBLE. CAREFULLY ARRANGE WIRING TO LIE ALONG THE EDGE OF THE PRODUCT OR BOX, KEEP THE CENTRAL AREA CLEAR. PUSH BACK UNIT INTO MOUNTING BOX MAKING SURE CONDUCTORS ARE NOT TRAPPED.


	Live (red pre Apr 04 / brown after Apr 04)
	Neutral (black pre Apr 04 / blue after Apr 04)
	Earth (yellow and green)

4 A) 13A SWITCHED FUSED CONNECTION UNIT



* This fused connection unit is fitted with two linked terminals to provide a dual earth facility. This is for use in "clean earth" installations where additional earth capacity is required to comply with regulation 607 of BS 7671 IET wiring regulations.


4 4 B) 13A SWITCHED FUSED CONNECTION UNIT W/FLEX OUTLET



5 USE A CROSS HEAD ELECTRIC OR MANUAL SCREWDRIVER TO FIT THE SPECIAL COUNTERSUNK SCREWS UNTIL TIGHT.*




CAUTION:
To reduce the risk of discolouration or tarnishing, avoid installation on wet plaster.



* Please ensure screws are sufficiently tight to support the product but please do not over tighten as this may cause some deformation to the plate or damage the screw.

6 By hand, screw the coin caps into the end of the screws. Use the plastic coin cap tool to fully tighten the coin caps.**





** Do NOT use a standard screw driver to tighten the coin caps. This may damage the cap and is not covered under warranty. Plastic coin cap tool must be used by hand only.

7 TURN POWER BACK ON.



REPLACING THE FUSE:

To avoid damaging the decorative coin cap screws, always remove coin cap when replacing the fuse



[end. **ORDINARY**]