

Scan for Capax panel website page

LAYOUT RESTRICTIONS ON LIGHTING DIFFUSERS IN SUSPENDED CEILINGS				
Maximum classification of lower surface	Use of space below the diffusers	Maximum area of each diffuser panel	Max total area of diffuser panels as percentage of floor area of the space in which the ceiling is located	Minimum separation distance between diffuser panels
TP (a)	Any except protected stairway	No limit	No limit	No limit
TP (b)	Rooms	5.sq m	50	3m
TP (b)	Circulation spaces except protected stairways	5.sq m	15	3m

EVENTUALLY, YOU MAY WANT TO REPLACE THIS PRODUCT

Regulations require the recycling of Waste from Electrical and Electronic Equipment (European "WEEE Directive" effective August 2005—UK WEEE Regulations effective February 2014). Environment Agency Registered Producer: WEE/GA0248QZ.

WHEN YOUR PRODUCT COMES TO THE END OF ITS LIFE OR YOU CHOOSE TO REPLACE IT, PLEASE RECYCLE IT WHERE FACILITIES EXIST - DO NOT DISPOSE WITH HOUSEHOLD WASTE.

CLEANING

Clean this fitting only with a soft dry cloth.

Do not use any chemical or abrasive cleaners.

IF YOU EXPERIENCE PROBLEMS

If you believe your product is defective, please return it to the place where you bought it. Our Technical Team will gladly advise on any Eterna Lighting product, but may not be able to give specific instructions regarding individual installations.



Email: sales@eterna-lighting.co.uk / technical@eterna-lighting.co.uk
Visit our website: www.eterna-lighting.co.uk
Made in China



INSTALLATION INSTRUCTIONS

A guide for qualified electricians



Model: Capax 1200x600 TP(a) UGR19 Power CCT Selectable Back Lit Panel



These instructions are provided as a guideline to assist you. PLEASE READ THESE INSTRUCTIONS BEFORE INSTALLATION AND RETAIN FOR FUTURE REFERENCE

Issue 0624

READ THIS FIRST

Check the pack and make sure you have all of the parts listed on the front of this booklet. If not, contact the outlet where you bought this product.

As the buyer, installer and /or user of this product it is your own responsibility to ensure that this fitting is fit for the purpose you have intended. Eterna Lighting Limited cannot accept any liability for loss, damage or premature failure resulting from inappropriate use.

This unit is suitable for indoor use only.

This Product is designed for permanent connection to fixed wiring: which must be a suitable circuit, protected with the appropriate MCB or fuse.

INSTALLATION

This product must be installed by a qualified electrician in accordance with the current building and IET Wiring Regulations

Do not connect to a circuit which has inductive loads connected. Switching of conductive loads will generate spikes in the supply which may damage electronic components within the driver.

- 1. Switch off the mains power before commencing installation. Lock off the MCB or remove the appropriate circuit fuse.
- 2. Remove terminal cover from input side of driver and make connections in accordance with the following code:

Live - Brown wire marked (L)

Neutral - Blue wire marked (N)

THIS PRODUCT IS DOUBLE INSULATED.

DO NOT CONNECT TO EARTH.

3. Select the required wattage to the output required by the Dip Switch.



4. Select the required Colour Temperature on the switch between the driver and panel.



- Ensure there are no loose strands of wire and all connections are onto the bared conductors and secure.
- 6. Replace input terminal cover on driver.
- 7. Install the fitting into the position within the suspended ceiling and laying safely onto the T-bar section of the ceiling grid.

8. Restore power and switch on to ensure fitting illuminates.

THE DRIVER MUST BE DISCONNECTED FROM THE ELECTRICAL SUPPLY BEFORE FLASH OR HIGH VOLTAGE TESTING.

